



FORM 195  
Rev. 11/06/2019

## COUNTY OF LOS ANGELES FIRE DEPARTMENT FIRE PREVENTION DIVISION

Fire Prevention Engineering  
5823 Rickenbacker Road  
Commerce, CA 90040  
Telephone (323) 890-4125 Fax (323) 890-4129

### Information on Fire Flow Availability for Building Permit

#### For One and Two Family Dwellings, Townhomes, and Accessory Dwelling Units

#### INSTRUCTIONS:

Complete parts I, II (A), and II (B).

Verifying fire flow, fire hydrant location and fire hydrant size.

#### PROJECT INFORMATION (To be Completed by Applicant)

#### PART I

Building Address: \_\_\_\_\_

City or Area: \_\_\_\_\_ APN \_\_\_\_\_

Nearest Cross Street: \_\_\_\_\_

Distance of Nearest Cross Street: \_\_\_\_\_

Property Owner: \_\_\_\_\_ Telephone: (    ) \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ Zip Code \_\_\_\_\_

Occupancy (Use of Building): \_\_\_\_\_ Sprinklered: Yes  No

Type of Construction \_\_\_\_\_

Square Footage: \_\_\_\_\_ Number of Stories: \_\_\_\_\_

\_\_\_\_\_  
Applicant's Signature

\_\_\_\_\_  
Date

**PART II (A) INFORMATION ON FIRE FLOW AVAILABILITY**  
**(Part II A and II B to be completed by Water Purveyor)**

The distance from the fire hydrant to the property line is \_\_\_\_\_  
feet via vehicular access. The fire flow services will be rendered from a \_\_\_\_\_  
inch diameter water main. The hydrant is located on \_\_\_\_\_  
\_\_\_\_\_ (Direction/side) \_\_\_\_\_ (Street)  
\_\_\_\_\_ of \_\_\_\_\_  
(Feet) (Direction) (Nearest Cross - Street)

Static PSI \_\_\_\_\_ Residual PSI \_\_\_\_\_ Orifice size \_\_\_\_\_ Pitot \_\_\_\_\_

Fire Flow at 20 PSI \_\_\_\_\_ for one hour duration  Flow Test Date / Time \_\_\_\_\_  
 Hydraulic model

Domestic Meter Size \_\_\_\_\_

---

**PART II (B)**

\_\_\_\_\_  
Water Purveyor Signature

\_\_\_\_\_  
Phone Number Date Title

---

**PART III Conditions for Approval by the Building Department**  
**(To be Completed by Building Department)**

The building permit may be issued for new or additions to detached one and two family dwellings, townhomes, and accessory dwelling units when the above information is completed and shows that the following minimum requirements are met and the property is not located in a Fire Hazard Severity Zone.

- The water system is capable of delivering at least 1000 GPM at 20 PSI for one-hour if non-sprinklered.
- The water system is capable of delivering at least 500 GPM at 20 PSI for one-half hour if sprinklered.
- The total area of the entire structure is less than 3,600 square feet.
- No portion of the lot frontage to the public fire hydrant shall exceed 450 feet via vehicular access.
- All portions of the proposed construction must be within 150 feet of a vehicular access roadway that is a minimum of 20 feet wide, paved with concrete or asphalt and does not exceed 15% grade.

\_\_\_\_\_  
APPROVED BY DATE OFFICE

**This Information is Considered Valid for Twenty Four Months**

When the project does not meet all of the above requirements for approval by the **Building Department**, the project must be sent to the **Fire Prevention Division** for approval before a Building Permit can be issued by the **Building Department**.