



**COUNTY OF LOS ANGELES FIRE DEPARTMENT  
FIRE PREVENTION DIVISION**

FORM 195  
Rev. 04/03

**Information on Fire Flow Availability for Building Permit**

**For Single Family Dwellings (R-3)**

**INSTRUCTIONS:**

Complete parts I, II (A) when:

Verifying fire flow, fire hydrant location and fire hydrant size.

Complete parts I, II (A), & II (B) when:

For buildings equipped with fire sprinkler systems, and/or private on-site fire hydrants.

**PROJECT INFORMATION  
(To be Completed by Applicant)**

**PART I**

Building Address: \_\_\_\_\_

City or Area: \_\_\_\_\_

Nearest Cross Street: \_\_\_\_\_

Distance of Nearest Cross Street: \_\_\_\_\_

Property Owner: \_\_\_\_\_ Telephone: (    ) \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ Zip Code \_\_\_\_\_

Occupancy (Use of Building): \_\_\_\_\_ Sprinklered: Yes      No

Type of Construction \_\_\_\_\_

Square Footage: \_\_\_\_\_ Number of Stories: \_\_\_\_\_

Present Zoning: \_\_\_\_\_

\_\_\_\_\_  
Applicant's Signature

\_\_\_\_\_  
Date

**PART II (A) INFORMATION ON FIRE FLOW AVAILABILITY**  
**(Part II to be completed by Water Purveyor)**

The distance from the fire hydrant to the property line is \_\_\_\_\_  
feet via vehicular access. The fire flow services will be rendered from a \_\_\_\_\_  
inch diameter water main. The hydrant is located on \_\_\_\_\_  
\_\_\_\_\_ (Street)  
\_\_\_\_\_ of \_\_\_\_\_  
(Feet) (Direction) (Nearest Cross - Street)

Under normal operating conditions the fire flow available from this \_\_\_\_\_  
hydrant is \_\_\_\_\_ GPM at 20 PSI residual for 2 hours at \_\_\_\_\_ PSI Static  
(Size)

**PART II (B) SPRINKLERED BUILDINGS ONLY**

Detector Location:(check one) Above Grade Below Grade Either  
Backflow protection required (fire sprinklers/private hydrant): Yes No  
Type of Protection Required:(check one)  
Double Check Detector Assembly Reduced Pressure Principal Detector Assembly  
Other \_\_\_\_\_ Domestic Meter Size \_\_\_\_\_

**PART II (C)**

\_\_\_\_\_  
Water Purveyor Signature  
\_\_\_\_\_  
Date Title

**PART III Conditions for Approval by the Building Department**  
**(To be Completed by Building Department)**

The building permit may be issued for single family dwellings when the above information is complete and shows that the following minimum requirements are met and the property is not in the Very High Fire Hazard Severity Zone.

The water system is capable of delivering at least 1250 GPM at 20 PSI for two hours.

The distance from the structure to the fire hydrant does not exceed 450 feet via vehicular access.

The proposed construction must be within 150 feet of a vehicular access roadway that is a minimum of 20 feet wide, paved with concrete or asphalt and does not exceed 15% grade.

\_\_\_\_\_  
APPROVED BY DATE OFFICE

**This Information is Considered Valid for Twelve Months**

Where the water service does not meet the above requirements for approval by the **Building Department, Fire Prevention Division** approval of the site plan will be required before a Building Permit can be issued by the **Building Department.**