



MARK PESTRELLA, Director

COUNTY OF LOS ANGELES

DEPARTMENT OF PUBLIC WORKS

"To Enrich Lives Through Effective and Caring Service"

900 SOUTH FREMONT AVENUE
ALHAMBRA, CALIFORNIA 91803-1331
Telephone: (626) 458-5100
<http://dpw.lacounty.gov>

ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 1460
ALHAMBRA, CALIFORNIA 91802-1460

IN REPLY PLEASE

REFER TO FILE:

BRC-1

June 14, 2017

REQUEST FOR PROPOSALS – ADDENDUM 2 SCRUBBER CONVERSION SERVICES (2017-AN010)

Please be reminded that the deadline to submit your Proposals is **Wednesday, June 21, 2017, at 5:30 p.m.**

Please take note of the following revision to the RFP for Scrubber Conversion Services (2017-AN010) issued on April 27, 2017. Please take note that the changes that have been added are in **boldface**.

All addenda and informational updates will be posted at <http://dpw.lacounty.gov/brcd/servicecontracts/>. Please check the website frequently for any changes to this solicitation.

ADDENDUM:

1. Exhibit A, Scope of Work, Section G. Work Description (Page A.3) has been amended by adding the following item:

17. Integrate County's existing chlorine detector to converted scrubber system's controls/operations so the dry scrubber shall activate when the chlorine detector indicates chlorine vapor is present. If County's existing chlorine detector does not function properly, the Contractor shall replace or repair the chlorine detector.

If you have questions concerning the above information, please contact Mr. David Pang at (626) 458-7167, dpang@dpw.lacounty.gov, Monday through Thursday, 7 a.m. to 5:30 p.m.

June 14, 2017
Page 2

Follow us on Twitter:

We encourage you to follow us on Twitter [@LACoPublicWorks](https://twitter.com/LACoPublicWorks) for information on Public Works and instant updates on contracting opportunities and solicitations.

Very truly yours,

MARK PESTRELLA
Director of Public Works



for: JOSE M. QUEVEDO
Assistant Deputy Director
Business Relations and Contracts Division

DP

P:\aepub\Service Contracts\CONTRACT\David\SCRUBBER CONVERSION PROJECT\2016\Proposers Conference\Addendum 2 6.7.17.docx

Enc.