



PROFILE ALIGNMENT AND GRADE OF
SANITARY SEWERS
 TO BE CONSTRUCTED IN
ALLEY THROUGH BLOCK B
TRACT No 10846
 M.B. 186-34-35
 IN THE COUNTY OF LOS ANGELES

RECOMMENDED *Edmund* APPROVED *Alfred*
 Chief Engineer City Engineer
PRIVATE CONTRACT NO. 62
 Approved *Alvarez*
 Chief Engineer of County
 Sanitation District No. 1

NOTE:
 Grades which this improvement is to be constructed are shown on this plan and profile. Grade points for the center line of street or center line of alley are shown in circles on profiles. All of work between designated points shall be established as to a center line shown between and designated points.
 Elevations are in feet above U.S.S. datum or mean sea level.
 Use prices for additional work which may be required, but which cannot be described in advance, shall be submitted in the proposal.
 The drawing and the data hereon, are hereby made a part of the specifications.

IN THIS CONTRACT CONSTRUCT FROM STA 0+00 TO STA 1+59.90 ON
 156 FEET 8" V.C.P. TOWER
 1" FLOORING MATERIAL WITH 5" STUDS
 5" ST. C.I. YS
 EXTEND 170 FEET 1/2" RED BRASS PIPE FROM WATER MAIN TO FLUSHING M.H. 4-7-3