



USE STANDARD STRENGTH PIPE
 USE CEMENT MORTAR FOR ALL VITRIFIED CLAY PIPE JOINTS
 CONSTRUCT HOUSE CONNECTIONS WITH INVERT AT CURB LINE
 6 FEET BELOW CURB GRADE EXCEPT AS NOTED
 ALL STRUCTURES SHALL BE BRICK FINER STRUCTURES AS PER PLAN NO. S-2-04
 USE STANDARD MANHOLE FRAMES AND COVERS AS PER PLAN NO. S-2-117
 IN ACCORDANCE WITH SURFACE TRENCH WITHIN PAVED AREA WITH PERMS ROCK AND OR 5\"/>

The County Engineer shall not be held responsible for location or existence of underground facilities

PROFILE, ALIGNMENT AND GRADE OF
SANITARY SEWERS
 TO BE CONSTRUCTED IN
WELLS STREET
 FROM 200 FT. TO 312 FT. EAST OF CHARLOTTE ST.

P.C. 1855

PLANS PREPARED BY *Paul G. Shuttle*
 JULY 1951

SHEET 1 OF 1 SHEETS

SCALE: VERTICAL 1\"/>

APPROVED: *H.L. Smelin* 8-2-51
 COUNTY ENGINEER
 APPROVED: *AN GARDIN*
 COUNTY SANITATION DISTRICT

Before breaking into any existing structure and before final acceptance of this work, County Sanitation District should be notified in order that required inspection may be made.

FOR LEGEND
 SEE PLAN NO. S-2-04

NOTE: GRADES TO WHICH THIS IMPROVEMENT IS TO BE CONSTRUCTED ARE SHOWN ON PLANS AND PROFILES. GRADE POINTS FOR TOP OF CURB, CENTER LINE OF STREET OR CENTER LINE OF ALLEY ARE SHOWN BY CIRCLES ON PROFILES AT ALL POINTS. BEYOND DESIGNATED POINTS THE GRADE SHALL BE ESTABLISHED SO AS TO CONFORM TO A STRAIGHT LINE DRAWN BETWEEN SAID DESIGNATED POINTS. ELEVATIONS ARE IN FEET ABOVE U. S. L. S. DATUM OR MEAN SEA LEVEL. ONLY PROFILES FOR ADDITIONAL WORK WHICH MAY BE REQUIRED BUT WHICH CANNOT BE ASCERTAINED IN ADVANCE SHALL BE SUBMITTED IN THE PROPOSAL. THIS DRAWING AND THE DATA HEREON ARE HEREBY MADE A PART OF THE SPECIFICATIONS.

6-C-1852

1-C-1000 J.C.

U.R. 42-12

July 1-3-52