

PRIVATE ENGINEER'S NOTICE TO CONTRACTORS

The existence and location of any underground utility or structure shown on these plans are obtained by a search of the available records. To the best of our knowledge there are no existing utilities except as shown on this map. The contractor is required to take due precautionary measures to protect the utility lines shown and any other lines not of record or not shown on this map.

Martin A. Lieberman R.C.E. 13168

No connections for the disposal of industrial wastes shall be made to sewers shown on these grawings without written permission from the Chief Engineer and General Manager

notified prior to the following so that required inspection can be made (Phone 337-1025 - - <del>038-116</del>1)

of the County Sanitation Districts.

Acceptance of the project.

## GENERAL NOTES:

- CURBS, CENTER LINE OF STREETS, OR CENTER LINE OF ALLEYS ARE SHOWN BY CIRCLES ON PROFILES. AT ALL POINTS BETWEEN DESIG-
- 7. BEFORE WORK CAN BE STARTED, THE CONTRACTOR MUST OBTAIN A PERMIT TO EXCAVATE IN COUNTY STREETS FROM THE L. A. COUNTY
- OF CONSTRUCTION INSPECTION AND RECORD PLANS.
- 8. IF WORK IS TO BE DONE IN A STATE HIGHWAY, A PERMIT MUST BE OBTAINED FROM THE STATE OF CALIFORNIA, DIVISION OF HIGH-
- THIS PROJECT. THIS NOTE APPLIES TO ALL PAGES.

## CONSTRUCTION NOTES:

- WITH .1.2.7.1.... SUPPLEMENTS) AND COUNTY ENGINEER SPECIAL PROVISIONS FOR THE CONSTRUCTION OF SANITARY SEWERS DATED 2. THE CONTRACTOR SHALL NOTIFY THE CONSTRUCTION DIVISION BY TELEPHONE, MADISON 9-4747, EXT. 81551, AT LEAST TWENTY-
- 3. HOUSE LATERALS TO BE CONSTRUCTED WITH INVERTS AT PROPERTY LINE 6 FEET BELOW CURB GRADE EXCEPT AS NOTED.
- 4. PROVIDE STAKES ON THE PROPERTY LINE OR PROPERTY LINES PRODUCED AT RIGHT ANGLES TO THE SEWER LINE AT THE CENTER LINE
- 7. MANHOLE TOPS IN UNIMPROVED RIGHTS OF WAY TO BE SIX INCHES ABOVE FINISHED GRADE.
- 8. VITRIFIED CLAY PIPE JOINTS SHALL BE TYPE "D", "F", OR "G" PER STANDARD SPECIFICATIONS SECTION 200-2.
- 9. IF A POWER POLE IS WITHIN THREE FEET OF THE SEWER, THE SEWER SHALL BE ENCASED, PER S-23, CASE II, TWO FEET ON EACH SIDE
- 10. IF DURING THE COURSE OF CONSTRUCTION IT IS DETERMINED THAT THERE IS LESS THAN FOUR FEET OF COVER OVER THE TOP OF A MAIN LINE OR HOUSE LATERAL V.C.P. SEWER WHICH IS NOT INDICATED ON THE PLANS, THE PIPE SHALL BE ENCASED PER S-23, CASE
- II UNLESS OTHERWISE APPROVED BY THE COUNTY ENGINEER. 11. ALL JOINTS BETWEEN CAST IRON PIPE AND VITRIFIED CLAY PIPE SHALL BE MADE WITH A RUBBER SLEEVE JOINT, TYPE "C" OR "B",
- 12. SEWERS TO BE TESTED FOR LEAKAGE PER SECTION 306-2.3.7 OF THE STANDARD SPECIFICATIONS AND SPECIAL PROVISIONS.
- 13. RESURFACE ALL TRENCHES WITHIN PAYED AREAS TO MEET LA. COUNTY ROAD DEPT. OR CALIFORNIA STATE HIGHWAY REQUIREMENTS

(WITH BUSHING IF NECESSARY) PER STANDARD SPECIFICATIONS, SECTION 208-2.

PROFILE, ALIGNMENT AND GRADE OF

SANITARY SEWERS PAGE 1

TO BE CONSTRUCTED IN

VISTA DEL MONTE MOBILE HOME PARK PRIVATE CONTRACT NO. 8657

> W.S. 46, 8-2 \_/\_SHEETS;\_2\_PAGES SCALE: VERT. 1"-4" DECEMBER, 1971
> PREPARED IN THE OFFICES OF

JENNINGS ENGINEERING CO., 44/9 VAN NUYS BLVO, SHERMAN OAKS, CA. BY: Martin a Liberton REG. C. E. No. 13/68

LEGEND ..... 8-1

NON-REINFORCED PRECAST CONCRETE MANHOLE

COUNTY OF LOS ANGELES, CALIFORNIA

TEMPLE CITY BLDG. DIST. 5.0

J. N. 037/./6\_

