COUNTY OF LOS ANGELES, CALIFORNIA

MEDDING REQUIREMENTS FOR PLASTIC PIPE

SANITARY SEWERS

TO BE CONSTRUCTED IN

ma ca no 19411 SAN DIMAS BLOG. DIST. 1000

DOUBLE SCALE

PRIVATE ENGINEER'S NOTICE TO CONTRACTORS

The existence and location of any underground utility pipes or structures shown on these plans are obtained by a search of the available records. To the best of our knowledge there are no exteting utilities except as shown on these plans. The contractor is required to take due proceutionary measures to protect the utility lines shown and any other lines not of record or not shown on these plans. The contractor shall be responsible for notifying "UNDERGROUND SERVICE ALERI" at 1-800-422-4133 two working days prior to any excevation or construction.

NO CONNECTION FOR THE DISPOSAL OF INDUSTRIAL WASTES SHALL BE MADE TO SEWERS SHOWN ON THESE DRAWINGS UNTIL Registered Engineer R.C.E. No. 19233 A PERMIT FOR INDUSTRIAL WASTEWATER DISCHARGE HAS BEEN ISSUED BY THE SANITATION DISTRICTS FOR SAID CONNECTION.

BM C.O. 3911 ELEV. 895.556

LATINE END C.B. 44 FT S + 96 FT W C/L INT GRAND AVE + DIAMOND BAR BLVD (HKD BM C-12)

MOICATE PLACE MUMBERS

INDEX MAP
TRACT Nº 42566
P.C. Nº 10364

BCALE: 1"-600"

BEFORE BREAKING INTO OR CONSTRUCTION ON A COUNTY SANITATION DISTRICT SEWER AND PRIOR TO FINAL ACCEPTANCE OF THE PROJECT, SANITATION DISTRICT INSPECTOR SHALL BE NOTIFIED BY PHONE 818 - 962-8605 SO THAT REQUIRED INSPECTION CAN BE MADE.

PERMITS UNTIL P.C. 10372 IS

ACCEPTED.

## GENERAL NOTES CONT'D.

12. ALL REFERENCE ON THIS PLAN TO THE COUNTY ENGINEER, THE ROAD DEPARTMENT, OR THE FLOOD CONTROL DISTRICT SHALL APPLY TO THOSE APPROPRIATE SECTIONS OF THE DEPARTMENT OF PUBLIC WORKS.

## CONSTRUCTION NOTES CONT'D.

- 18. A.B.S. SOLID WALL PIPE MUST BE USED FOR WYE AND HOUSE LATERAL.
  CONNECTIONS TO A.B.S. COMPOSITE MAINLINE SEVER PIPE.
- 20. THREE DEGREE DEFLECTION COUPLERS ARE REQUIRED FOR RADIUS OF CURVATURE LESS THAN 380 FEET WHEN USING 8" A.B.S. COMPOSITE
- 23. ALL WYES AND/OR HOUSE LATERALS ARE TO BE LOCATED AT LEAST FIVE FEET APART AND WHEN POSSIBLE NOT CLOSER THAN FIVE FEET
- TO ANY MANHOLE.
- 25. ONLY WYE BRANCHES ARE TO BE USED FOR CONNECTION TO A.B.S. COMPOSITE MAINLINE SEWER PIPE.

GENERAL NOTES:

1. ELEVATIONS ARE IN FEET ABOVE U.S.C. 4 G.S. SEA LEVEL DATUM OF 1939.

2. NO REVISIONS SHALL SE MADE IN THESE PLANS WITHOUT THE APPROVAL OF THE CUUNTY ENGINEER.

CURBS, CENTER LINE OF STREETS, OR CENTER LINE OF ALLEYS ARE SHOWN BY CIRCLES ON PROFILES AT ALL POINTS BETWEE &

AS SHOWN ON THE PLANS. HOUSE LATERALS FROM CHIMNEYS SHALL NOT MAYE AN ANGLE OF LESS THAN 46" WITH THE MAIN LINE

& THE PRIVATE ENGINEER SHALL PURNISH THE HOUSE LATERAL DEPTH AT THE PROPERTY LINE BELOW THE TOP OF CURB ELEVATION FOR

LOS ANGELES, CA 20020, TO COVER THE COST OF CONSTRUCTION INSPECTION AND RECORD PLANS.

& APPROVAL OF THIS PLAN BY THE COUNTY OF LOS ANGELES BOES NOT CONSTITUTE A REPRESENTATION AS TO THE ACCURACY OF

THE LOCATION OF OR THE EXISTENCE! I NON-EXISTENCE OF ANY UNDERGROUND UTILITY PIPE, OR STRUCTURE WITHIN THE LIMITS OF THIS PROJECT. THIS NOTE APPLIE. TO ALL PAGES. 18. REFER TO SECTION 7.18.4.1 OF THE STANDARD SPECIFICATIONS, REGARDING SAFETY ORDERS.

COUNTY ENGINEER COPIES OF A PERMIT TO EXCAVATE IN COUNTY STREETS FROM THE LOS ANGELES COUNTY ROAD DEPARTMENT, A PLININT FOR EXCAVATIONS AND TRENCHT'S FROM THE STATE OF CALIFORNIA. DIVISION OF INDUSTRIAL SAFETY AND A CERTIFICATE OF WORKER'S COMPENSATION INSURANCE WITH THE DEPARTMENT OF COUNTY ENGINEER, SED SOUTH VERMONT, RM. 408, LOS ANGELES, CALIFORNIA 80050, NAMED AS THE CERTIFICATE HOLDER TO BE NOTIFIED 30 DAYS PRIOR TO CANCELLATION OF POLICY.

8. WORK SHALL BE CONSTRUCTED ACCORDING TO THE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION (1982)
EDITION W 1984 SUPPLEMENTS) AND COUNTY ENGINEER SPECIAL PROVISIONS FOR THE CONSTRUCTION OF SANITARY SEWERS
DATED \_\_\_\_\_\_SE<sup>12</sup>T. 21, 1976 \_\_\_\_\_\_ AND SHALL BE PROSECUTED ONLY IN THE PRESENCE OF THE COUNTY ENGINEER. 2. THE CONTRACTOR SHALL NOTHER THE CONSTRUCTION DIV. PUBLIC WORKS DEPT. TEL. (23)226-8281 AT LEAST 24

7. MANHOLE TOPS IN UNIMPROVED RIGHTS OF WAY TO BE SIX INCHES ABOVE PINISHED GRADE. 8. VITRIFIED CLAY PIPE JOINTS SHALL BE TYPE "B" OR "B" PER STANDARD SPECIFICATIONS SECTION 200-2.

MAIN LINE OR HOUSE LATERAL SEWER WHICH IS NOT INDICATED ON THE PLANS, THE PIPE SHALL BE ENCASED PER S-SS, CASE II

PER A.S.T.M. STD. METHOD OF TEST DOGS.STT AS MODIFIED. ACCEPTABLE CERTIFICATION OF SUCH COMPACTION SHALL BE

BURNITTED TO THE CONSTRUCTION DIV. PUBLIC WORKS DEPT.

THOMAS A. TIDEMANSON, DIRECTOR DEPARTMENT OF PUBLIC WORKS



